



Method of procedure

Prepared by: Weston Jenkins

Start Date: 8/7/2026

What is the work to be performed? Shut down campus domestic water system to perform a valve replacement on the
McCloud Hall building.

Why does the system need to be taken off line?

No isolation valves are available to shutdown this portion of the system.

Who needs to be notified? IOR Owner PM ETC.

Contact number

1. Veronica Rivera
2. Nick Trover
3. Calvin Jackson IOR
4.

530-905-0265
530-519-7132
530-815-4460

Identify shutdown location & procedure for affected systems.


1. Shut down boilers and effected equipment.
2. Remove steel cover at Gym Building entrance and shut blue gate valve at water meter.
3. Purge system, R&R valve.
4. Connect lines to put back in service.
5.

Proposed Duration of shutdown

8 hours. We request to start at 7:00am and will aim to have system back on line 3:00

Startup procedure

1. Turn main valve back on while maintaining leak detection
2. Open all sinks to remove any residual air in system.
3.
4.
5.

Authorized by Director of Facilities Signature  Date 8-5-2026